

County of Henry

P.O. BOX 7
COLLINSVILLE, VIRGINIA 24078-0007
<http://www.co.henry.va.us/>

TELEPHONE (276) 634-4670
FAX (276) 634-4535



MEMBER OF
VAGP
NIGP

PURCHASING DEPARTMENT

December 14, 2018

NOTICE TO BIDDERS

Invitation to Bid #18-12183-3051 for "Installation of Roof and Associated Material for Magna Vista High School New Weight Room, Opening Date December 18, 2018 at 3:00 p.m. Local Prevailing Time

ADDENDUM #1

Please see the attached sheet regarding changes in the specifications and extension of bid opening date.

This Addendum Must Be Signed and Returned With Your Bid.

COMPANY NAME _____

SIGNATURE _____

PRINT NAME _____

DATE _____

CAROLE JONES ^{cy}
CHIEF PURCHASING AGENT

IFB Number: 18-12183-3051

Due Date: December 18, 2018 (3:00 PM Local Prevailing Time)

**Installation of Roof and Associated Material for Magna Vista High School
New Weight Room**

Addendum No. 1

1. Contractor shall include hanging the precast panels as part of this bid so the EPDM roofing can go over the top of the panels and be secured on the outside face and covered with the Aluminum flashing. Flashing color to be picked out by Henry County Schools Personnel.
2. Contractor shall confirm the bar joist bearing plates have been installed in the bond beam.
3. Contractor shall include reworking the corners to accept the W18 x 55 beam across the storefront wall if this area is not installed correctly.
4. The contractor will rough in roof drains per drawings below the decking and HCPS staff will make the final tie-ins.
5. Replace first paragraph of bid document to read: Sealed bids, subject to the specifications and conditions contained herein and attached hereto, will be received at the above office until, but not later than **3:00pm**, local prevailing time, **January 10, 2019**, and then publicly opened and read in room 210 (bid room) of the same office, for installation of roof and associated material for Magna Vista High School new weight room.